

COAT HOOKS

H2-104



SUTTER HEALTH - PHYSICAL ACCESS COMPLIANCE

H2 Number

AUTHOR: BILL ZELLMER

ISSUE DATE: 7-28-2015

APPLICABLE CODES: 2010 ADA & 2019 CBC

REVISED DATE: 10-16-2019

CBC CODE SECTIONS: 11B-603.4

- A: RECOMMEND PLACING COAT HOOK TOP AT 46" ABOVE FLOOR AT CENTERLINE OF DOOR. CODE REQUIRES THAT THEY BE PLACED WITH OPERABLE PARTS AT 48" MAXIMUM HEIGHT.
- B: ALTERNATE LOCATION: COAT HOOKS MAY ALSO BE PLACED ON WALL, SET HOOK TOP AT 46" ABOVE FLOOR. CODE REQUIRES THAT THEY BE PLACED WITH OPERABLE PARTS AT 48" MAXIMUM HEIGHT.
- C: SECOND HOOK: A SECOND HOOK MAY BE PROVIDED AT THE DISCRETION OF THE FACILITY, NO SPECIFIC HEIGHT IS MANDATED BY CODE, 60" IS RECOMMENDED.
- D: ALLOWABLE RANGE: ALL OPERABLE PARTS MUST BE WITHIN A 15' MIN. AND 48" MAX. HEIGHT ABOVE THE FLOOR

