

# PAPER TOWEL & SOAP DISPENSERS AT TOILET ROOMS

H2-108



## SUTTER HEALTH - PHYSICAL ACCESS COMPLIANCE

H2 Number

AUTHOR: BILL ZELMER

ISSUE DATE: 7-25-2015

APPLICABLE CODES: 2010 ADA & 2019 CBC

REVISED DATE: 10-19-2019

CBC CODE SECTIONS: 11B-603.5 AND 11B-604.3.2

- A: RECOMMEND PLACING PAPER TOWEL DISPENSER W/ BOTTOM AT 3'-3" (39") ABOVE FLOOR. ALIGN FRONT OF DISPENSER WITH FRONT EDGE OF LAVATORY OR COUNTER. CODE REQUIRES THAT THEY BE PLACED WITH OPERABLE PARTS (PAPER TOWELS) AT A 40" MAXIMUM HEIGHT.
- B: RECOMMEND PLACING SOAP DISPENSER W/ BOTTOM AT 3'-3" (39") ABOVE FLOOR. CODE REQUIRES THAT THEY BE PLACED WITH OPERABLE PARTS AT A 40" MAXIMUM HEIGHT. BE SURE TO MAINTAIN 60" CLEARANCE TO SIDEWALL.
- C: ALTERNATIVE LOCATION: PAPER TOWEL AND/OR SOAP DISPENSER MAY ALSO BE PLACED ON WALL-SIDE OF MIRROR. CONFIRM THAT SOAP AND PAPER TOWEL DISPENSERS DO NOT INTERFERE WITH EACH OTHER.
- D: IF USING LARGE PAPER DISPENSERS, SET BOTTOM OF DISPENSER AT 3'-5" (41") ABOVE FLOOR. THE OPERABLE PART HEIGHT MAY BE CONSIDERED AS THE POINT AT WHICH THE SENSOR DETECTS MOTION AND DISPENSES PAPER TOWELS WHICH ARE PHYSICALLY WITHIN THE 3'-4" (40") HEIGHT ABOVE FLOOR. RECOMMEND MAXIMIZING HEIGHT ABOVE COUNTER TO PROVIDE MAXIMUM WORKING CLEARANCE ABOVE COUNTER.

