

PATIENT CHANGE AREAS						SAG 7
Author:	Bill Zellmer AIA, CASp	Issue Date:	January 5, 2015	Sutter Health - Physical Access Compliance		
	Sutter PAC Group	Revisions:	August 1, 2024	Sutter Accessibility Guidance		
Topic No.	Topic Name	Brief Description	2022 CBC - Code Text:	2010 ADA Standards - Text:	Sutter Guidance	Additional Information
1	Patient Change Areas - Code Text	The code does not define 'patient change areas' which causes confusion.	CBC Section 11B-805.5 Patient change areas. Areas where patients change or are prepared for a procedure shall comply with Section 11B-222.	None.	This section of code is intended to require an accessible changing area where the medical treatment or procedure requires a full-body change of clothing.	None.
2	De-Facto Dressing Rooms	The intent of this code section is to enforce the dressing room accessibility requirements of 11B-222 on rooms or areas that are intended for changing clothes, but not actually identified as a 'dressing room'. Example: A dressing alcove with a curtain around it, but no bench, coat hook or mirror, with the explanation that 'It is not a dressing room, it just a place where we have patients change clothes'.	Same.	None.	Any areas that are specifically designed and intended for changing clothes, shall be designed in accordance with the dressing room accessibility requirements of Section 11B-222 and by cross-reference 11B-803.	None.
3	Not required at Patient Bedrooms and Exam Rooms	The code text can be misunderstood to imply that the dressing room requirements must be applied at any and every location that patients <u>might</u> change some article of clothing, including patient bedrooms and exam rooms.	N/A	None.	Code Section 11B-805.5 does <u>not</u> create an obligation to provide benches, coat hooks and mirrors in rooms or areas that are <u>not designed and intended</u> for changing clothes to perform a medical procedure. Specifically, this code section does not require these features in an exam room or patient bedroom.	None.

PATIENT CHANGE AREAS						SAG 7
Author:	Bill Zellmer AIA, CASp	Issue Date:	January 5, 2015	Sutter Health - Physical Access Compliance		
	Sutter PAC Group	Revisions:	August 1, 2024	Sutter Accessibility Guidance		
Topic No.	Topic Name	Brief Description	2022 CBC - Code Text:	2010 ADA Standards - Text:	Sutter Guidance	Additional Information
4	Scoping	5%, minimum of one of each element shall be accessible. This scoping requirement is understood to apply universally, whether or not the room is labelled as a 'dressing room' or not.	CBC 11B-222 Dressing, fitting and locker rooms. 11B-222.1 General. Where dressing rooms, fitting rooms, or locker rooms are provided, at least 5%, but no fewer than one of each type of use in each cluster provided shall comply with 11B-803.	ADAS 222 Dressing, fitting and locker rooms. 222.1 General. Where dressing rooms, fitting rooms, or locker rooms are provided, at least 5%, but no fewer than one of each type of use in each cluster provided shall comply with 803.	Per 11B-222 at least 5% but no fewer than one of each type of each 'dressing' element provided must be accessible at each location where they are provided.	None.