

# Coat Hooks

H2-104



SUTTER HEALTH – PHYSICAL ACCESS COMPLIANCE

H2 NUMBER

AUTHOR: BILL ZELLMER

ISSUE DATE:

7-28-2015

APPLICABLE CODES: 2010 ADA & 2013 CBC

REVISIONS:

N/A

CBC CODE SECTIONS: 11B-603.4

- A: RECOMMEND PLACING COAT HOOK TOP AT 46 INCHES ABOVE FLOOR AT CENTERLINE OF DOOR. CODE REQUIRES THAT THEY BE PLACED WITH OPERABLE PARTS AT A 48 INCHES MAXIMUM HEIGHT.
- B: ALTERNATE LOCATION: COAT HOOKS MAY ALSO BE PLACED ON WALL, SET TOP OF HOOK AT 46 INCHES ABOVE FLOOR. CODE REQUIRES THAT THEY BE PLACED WITH OPERABLE PARTS AT A 48 INCH MAXIMUM HEIGHT.
- C: SECOND HOOK: A SECOND HOOK MAY BE PROVIDED AT THE DISCRETION OF THE FACILITY, NO SPECIFIC HEIGHT IS MANDATED BY CODE, 60 INCHES IS RECOMMENDED.
- D: ALLOWABLE RANGE: ALL OPERABLE PARTS MUST BE WITHIN A 15 INCH MINIMUM AND 48 INCH MAXIMUM HEIGHT ABOVE THE FLOOR.

