

Hand Sanitizers

H2-107



SUTTER HEALTH – PHYSICAL ACCESS COMPLIANCE

H2 NUMBER

AUTHOR: BILL ZELLMER

ISSUE DATE:

7-28-2015

APPLICABLE CODES: 2010 ADA & 2013 CBC

REVISIONS:

N/A

CBC CODE SECTIONS: 11B-307, 11B-308 AND 11B-309

- A: RECOMMEND PLACING HAND SANITIZERS WITH A MINIMUM OF 3 INCHES TO ANY OTHER WALL-MOUNTED OBJECTS, SPECIFICALLY INCLUDING BRAILLE SIGNAGE. NOTE: DO NOT PLACE HAND SANITIZERS UNDER BRAILLE BECAUSE IT WOULD INTERFERE WITH THE ABILITY TO READ THE BRAILLE.
- B: RECOMMEND A MINIMUM OF 1 FOOT TO 8 INCHES (20 INCHES) CLEAR TO THE SIDE OF ANY DOOR JAMB. CODE REQUIRES A MINIMUM OF 1 FOOT TO 6 INCHES (18 INCHES) CLEAR ON THE PULL SIDE OF DOOR JAMBS.
- C: RECOMMEND A MAXIMUM 4 INCH DEEP PROJECTION FROM THE WALL SURFACE. CODE REQUIRES: THAT A MAXIMUM OF 4 INCHES IS ALLOWED FOR OBJECTS THAT MAY CONSTITUTE A PROTRUDING OBJECT TO THOSE WHO ARE SIGH-IMPAIRED.
- D: RECOMMEND SETTING HIGHEST OPERABLE PART AT 3 FEET TO 10 INCHES (46 INCHES) ABOVE THE FLOOR. ALLOWABLE RANGE: ALL OPERABLE PARTS MUST BE WITHIN A 15 INCH MINIMUM AND 48 INCH MAXIMUM HEIGHT ABOVE THE FLOOR.

